**RHKF-U** 

### Light intensivity sensor

# Room or outside light intensivity sensor

### **General description**

**Features** 

A light intensity sensor PHOTASGARD® RHKF with four switchable measuring ranges (four devices in one) measures the luminous intensity and is used to control luminaries, lighting systems, Venetian blinds and canvas blinds, etc., to monitor lighting conditions at workplaces, in storage halls, workshops and corridors, in indoor areas, in industrial halls, in offices as well as in residential and business facilities, for daylight- dependent constant light control, as light intensity or twilight sensor and to control sunshade equipment avoiding unnecessary heating-up of rooms. Therefore it minimizes your variety of types and stock keeping while covering a greater range of universal applications. The sensor used in PHOTASGARD® light intensity sensors was specifically adapted to the sensitivity of the human eye. Its greatest sensitivity is in the range of 350 nm to 820 nm. Therefore with its special filter the sensor is predestined for exposure measurement of daylight and/or for measuring artificial light of high color temperature (similar to sunlight). The case of the sensor is hermetically tight, the vision panel is protected by a glass plate.

#### 1/2

Connects to:	HC-IQ - IW0
Mounting:	On wall
Dimensions:	91 × 85 × 27 mm

Model number: RHKF-U

## Applications

Ready light lightness detector





# **Technical specifications**

Power supply	1536 VDC
Power consumption	<1 W @ 24 VDC
Sensor	light sensor with difuser
Output	0-10 V
Measuring error	<5% full scale
Temperature	0°C ~ 50 °C
Dimensions	91 x 85 x 27 mm
Protection class	III
Protection type	IP 30

# Terminals

Power supply	1 + 24 VDC power supply input	
	<b>3</b> GND power supply input	
HC-IQ analog input	2 Output light intensivity 0-10V (linearised)	
		0.55 KLux 20 KLux 20 KLux 20 KLux
		Offset

From: http://wiki.hiq-universe.com/ -

Permanent link: http://wiki.hiq-universe.com/doku.php?id=en:hiq\_hw:rhkf-u&rev=1563950351



Last update: 2019/07/24 06:39